

| Wells County Public Library 2024 |              |                 |                      |             |                            |                               | Updated 8/21/2020        |            |                                     |
|----------------------------------|--------------|-----------------|----------------------|-------------|----------------------------|-------------------------------|--------------------------|------------|-------------------------------------|
| <u>FHI</u>                       | <u>Make</u>  | <u>Model</u>    | <u>Serial Number</u> | <u>Belt</u> | <u>Filter</u>              | <u>Location</u>               | <u>Equipment</u>         | <u>Age</u> | <u>Condition</u>                    |
| 2                                | Weil McClain | 299-CTNG-M      | 3                    |             |                            | Upstairs East End             | Hot Water Boiler         | 2014       | 2026+                               |
| 3                                | Weil McClain | M-299           | 3-UE                 |             |                            | Upstairs East End             | Hot Water Boiler         | 2014       | 2026+                               |
| 155                              |              |                 |                      |             |                            | Upstairs East End             | Hot Water Circ. Pump     | 2022/23    |                                     |
| 165                              |              |                 |                      |             |                            | East Boiler Room              | Valve                    |            |                                     |
| 167                              |              |                 |                      |             |                            | East Boiler Room              | Hot Water Expansion Tank |            |                                     |
| 7                                | Trane        | YSC092F4RHA06   | 133211021L           | A34         | (4)20x25x2                 | Roof On East End              | RTU-Gas/Eelectric        | 8/21/2013  | 2026+                               |
| 16                               | American St  | TWH060P15000    | E22547720            |             | (1)16x20x1<br>(1)16x25x1   | Equip. Room OverHead          | Heat Pump/Indoor AHU     | 3/11/1991  | Expect Replacement on Major Repairs |
| 9                                | American St  | TWA060A300A2    | 133                  |             |                            | Roof East End for Coffee Shop | Heat Pump Outdoor Unit   | 3/11/1991  | Expect Replacement on Major Repairs |
| 8                                |              |                 |                      |             |                            | East High Roof                | Exhaust Fan              |            | Age Unknown                         |
| 10                               |              |                 |                      |             |                            | East Equipment Closet         | Gas Water Heater         |            | Age Unknown                         |
| 6                                |              |                 |                      |             |                            | East Equipment Closet         | Hot Water Circ. Pump     |            | Age Unknown                         |
| 12                               |              |                 |                      |             |                            | Generator/ Electrical Room    | Exhaust Fan              |            | Less Than 5 Years Remaining (2026)  |
| 14                               |              | UHSA090W2EAA1T  |                      |             |                            | Garage                        | Hydronic Unit Heater     | 3/11/1991  | Expect Replacement on Major Repairs |
| 15                               |              | UHSA-070W2C-AAE | D90M16772            |             |                            | Garage                        | Hydronic Unit Heater     | 3/11/1991  | Expect Replacement on Major Repairs |
| 169                              |              |                 |                      |             |                            | Entrance by Doors             | Hydronic Cabinet         |            | Less Than 5 Years Remaining (2026)  |
| 20                               | Trane        | YSC036E4RHA1M   | 133411037L           | AX26        | (2)20x30x2                 | Roof West end RTU5            | RTU-Gas/Eelectric        | 8/21/2013  | 2026+                               |
| 19                               | Trane        | YSC092F4RHA07   | 133412418L           | AX35        | (4)20x25x2                 | Roof West Side RTU6           | RTU-Gas/Eelectric        | 8/21/2013  | 2026+                               |
| 22                               | Trane        | YSC036E4RHA1M   | 133411061L           | AX26        | (2)20x30x2                 | Roof West End RTU7            | RTU-Gas/Eelectric        | 8/21/2013  | 2026+                               |
| 21                               | Trane        | YSC036E4RHA1M   | 133411085L           | AX26        | (2)20x30x2                 | Roof West End RTU8            | RTU-Gas/Eelectric        | 8/21/2013  | 2026+                               |
| 25                               | Lochinvar    | EBN300          | D06H00186332         |             |                            | West End Equipment Room       | Hot Water Boiler         | 2024       | 2036+                               |
| 26                               | Lochinvar    | EBN300          | D06H00186331         |             |                            | West End Equipment Room       | Hot Water Boiler         | 2024       | 2036+                               |
| 30                               |              | EJMM3157T       | 35L5C9T866           |             |                            | West End Above Geneology      | Hot Water Circ. Pump     | 2024       | Rebuilt 2024 (2029+ years)          |
| 31                               |              | EJMM5157T       | 35I509T866           |             |                            | West End Above Geneology      | Hot Water Circ. Pump     |            | Less Than 5 Years Remaining (2026)  |
| 166                              |              |                 |                      |             |                            | West Boiler Room              | Valve                    |            |                                     |
| 27                               |              |                 |                      |             |                            | West Equipment Room           | Electric Water           |            | Age Unkown                          |
| 157                              |              |                 |                      |             |                            | West End Equipment Room       | Hot Water Circ. Pump     |            | Less Than 5 Years Remaining (2026)  |
| 28                               |              | SQ-140-B        | 106436170610         |             |                            | West End Equipment Room       | Exhaust Fan              |            | Age Unkown                          |
| <u>FHI</u>                       | <u>Make</u>  | <u>Model</u>    | <u>Serial Number</u> | <u>Belt</u> | <u>Filter</u>              | <u>Location</u>               | <u>Equipment</u>         |            |                                     |
| 24                               |              | MCCB0300A0COUA  | K06F72326            | (2)5VX80C   | (12) 20X20X2<br>(4)20X25X2 | West End Equipment Room       | Air Handler              | 7/17/2006  | Replaced coil/condeser 2022 (2037+) |
| 176                              |              |                 |                      |             | (1)20x20x1                 | Collections                   | VAV Box                  | 7/17/2006  | Less Than 5 Years Remaining (2026)  |
| 177                              |              |                 |                      |             | (1)20x20x1                 | Collections                   | VAV Box TB4-             | 7/17/2006  | Less Than 5 Years Remaining (2026)  |
| PM                               |              |                 |                      |             |                            |                               |                          |            |                                     |
| 178                              |              |                 |                      |             | (1)20x20x1                 | Collections                   | VAV Box TB4-3            | 7/17/2006  | Less Than 5 Years Remaining (2026)  |
| 179                              |              |                 |                      |             | (1)16x20x1                 | Childrens Office              | VAV Box TB4-4            | 7/17/2006  | Less Than 5 Years Remaining (2026)  |
| 180                              |              |                 |                      |             | (1)16x20x1                 | Storage Work Room             | VAV Box TB4-5            | 7/17/2006  | Less Than 5 Years Remaining (2026)  |

|     |        |                 |            |      |                          |               |                 |           |                                    |
|-----|--------|-----------------|------------|------|--------------------------|---------------|-----------------|-----------|------------------------------------|
| 181 |        |                 |            |      | (1)20x20x1               | Young Adult   | VAV Box TB4-6   | 7/17/2006 | Less Than 5 Years Remaining (2026) |
| 182 |        |                 |            |      | (1)16x20x1               |               | VAV Box TB4-7   | 7/17/2006 | Less Than 5 Years Remaining (2026) |
| 183 |        |                 |            |      | (1)20x20x1               |               | VAV Box TB4-8   | 7/17/2006 | Less Than 5 Years Remaining (2026) |
| 184 |        |                 |            |      | (1)16x20x1               |               | VAV Box TB4-9   | 7/17/2006 | Less Than 5 Years Remaining (2026) |
| 185 |        |                 |            |      | (1)16x20x1               |               | VAV Box TB4-10  | 7/17/2006 | Less Than 5 Years Remaining (2026) |
| 186 |        |                 |            |      | (1)16x20x1               |               | VAV Box TB4-11  | 7/17/2006 | Less Than 5 Years Remaining (2026) |
| 187 |        |                 |            |      | (1)16x20x1               |               | VAV Box TB4-12  | 7/17/2006 | Less Than 5 Years Remaining (2026) |
| 188 |        |                 |            |      | (1)16x20x1               |               | VAV Box TB4-13  | 7/17/2006 | Less Than 5 Years Remaining (2026) |
| 154 | Trane  | YSD300F4RLA0300 | 141310158D | BX81 | (4)20x25x2<br>(4)20x20x2 | Roof          | RTU-Gas/Electic | 3/31/2014 | 2026+                              |
|     | NewRTU |                 |            |      |                          | North Non-Fic | RTU Gas/Electic | 2020      | 15+ Years Remaining (2035+)        |